

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130723-E56677  
**Report Reference** E56677-19980918  
**Issue Date** 2013-JULY-23

**Issued to:** ITT AEROSPACE CONTROLS, UNIT OF ITT FLUID  
TECHNOLOGY CORP  
28150 INDUSTRY DR  
VALENCIA CA 91355


**This is to certify that  
representative samples of** SNAP SWITCHES FOR USE IN HAZARDOUS  
LOCATIONS  
SEE ADDENDUM PAGE

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for  
Use in Class I and II, Division 2 and Class III, Divisions 1  
and 2 Hazardous (Classified) Locations

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)




# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20130723-E56677  
**Report Reference** E56677-19980918  
**Issue Date** 2013-JULY-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Enclosed Adjustable Pressure-Operated Switches, Standard Series 100P followed by 1, 4, 5 or 9; followed by 1, 2, 4, 5, 7 or 8; followed by C or CC; followed by 5; followed by B, C, A, E, F, M, O, S or W for use in Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F and G; Class III Hazardous Locations.

Special Series 100P followed by 1, 4, 5 or 9; followed by S; followed by suffixes up to four digits for use in Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F and G; Class III Hazardous Locations.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

