

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

057-0057, 057-130 & 057-0157. Neo-Dyn Snap Switches.

XP / I / 1 / ABCD / T6; DIP / II / 1 / EFG / T6

057-690, 057-691, 057-692, 057-693, 057-696, 057-697, 057-698 & 057-699. Neo-Dyn Snap Switches.

XP / I / 1 / ABCD / T6; DIP / II,III / 1 / EFG / T6

057-0760, 057-0761, 057-0762, 057-0763, 057-0770, 057-0771, 057-0772 & 057-0773. Neo-Dyn Snap Switches.

XP / I / 1 / ABCD / T6; DIP / II / 1 / EFG / T6 (See Special Conditions) Ta = (See Special Conditions); IP66.

Special Conditions of Use:

1. Model 057-0770 has Temperature Classification T5 for 11Amp, and T6 for 5 Amp.
2. Model 057-0771 has Temperature Classification T4 for 11Amp, and T6 for 5 Amp.
3. Ambient temperature is based on the model code.
 - 3.1 For Models 057-0762, 057-0763, 057-0772 and 057-0773, Ta = 70°C.
 - 3.2 For Model 057-0760 (11A), Ta = 60°.
For Model 057-0760 (5A), Ta = 70°.
 - 3.3 For Model 057-0761(11A), Ta = 45°.
For Model 057-0761(5A), Ta = 70°
 - 3.4 For Model 057-0770 (11A), Ta = 75°.
For Model 057-0770 (5A), Ta = 70°.
 - 3.5 For Model 057-0771(11A), Ta = 65°.
For Model 057-0771(5A), Ta = 70°.

Equipment Ratings:

Explosionproof for Class I, Division 1, Groups A, B, C and D; T6 and Dust-Ignitionproof for Class II, Division 1, Groups E, F and G, T6 hazardous (classified) locations.

FM Approved for:

ITT Aerospace Controls
Valencia, CA 91355

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005


Original Project ID: 1R5A9.AE


Approval Granted: June 21, 1990

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
2D1A0.AE	June 18, 1997		
2D6A4.AE	September 30, 1997		
3004277	June 16, 1999		
3016301	June 12, 2003		
070405	May 8, 2007		
071210	January 3, 2008		

FM Approvals LLC


Richard P. Ferron, P.E.
Group Manager


Date