



Neo-Dyn®
28150 Industry Drive
Valencia, CA, 91355
661-295-4000

4/4/2013

Hydrostatic Pressure Test

ITT Neo-Dyn industrial pressure switches are subjected to a proof test procedure where 125% of the rated maximum proof pressure is applied to the product before it leaves the facility. This is a value that is a minimum of 187.5% of the rated maximum operating pressure. This procedure is applied to 100% of every industrial pressure switch manufactured here at ITT Neo-Dyn.

Eloiza G. Sierra

Eloiza Sierra

Quality Engineer